

MODEL	REIMS GRIS 45X45 EXT		
SIZE	45 x 45		
PRODUCT	Porcelain. Group Bla		
DESCRIPTION OF TEST	TEST VALUE	alaplana. CERÁMICA	TEST STANDARD
WATER ABSORTION	AA < 0,5%	Pass	UNE-EN-ISO 10545-3
BREAKING STRENGHT	> 1300 N	Pass	UNE-EN-ISO 10545-4
MODULUS OF RUPTURE	> 35 MPa	Pass	UNE-EN-ISO 10545-4
RESISTANCE TO SURFACE ABRASION	Class & Number of Revolutions	PEI IV (1500)	UNE-EN-ISO 10545-7
CRAZING RESISTANCE	Demanded	Pass	UNE-EN-ISO 10545-11
FROST RESISTANCE	Available Method	Pass	UNE-EN-ISO 10545-12
CHEMICAL RESISTANCE (Cleaning & Swimmingpool Products) RESISTANCE (Acid & Alkaline Low Concentration) (Acid & Alkaline High Concentration)	Minimum GB	Pass	UNE-EN-ISO 10545-13
RESISTENCE TO STAINS	Minimum Class 3	Pass	UNE-EN-ISO 10545-14
SLIP RESISTANCE	Available Method	R11	UNE-ENV 12633:2003
RESISTANCE TO DEEP ABRASION	Minimum 3	Pass	EN 101